

Jackson Valley  
Irrigation District

(JVID)

2023

ANNUAL

WATER QUALITY

REPORT

# 2023 Consumer Confidence Report

Water System Name: Jackson Valley Irrigation District (JVID) Report Date: March 1, 2024

*We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1, 2023 to December 31, 2023 and may include earlier monitoring data.*

*Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse Jackson Valley Irrigation District (JVID) | 6755 Lake Amador Dr. Ione, CA 95640 | a (209) 274-2037 para asistirlo en español.*

Type of water source(s) in use: Surface Water

Name & general location of source(s): Lake Pardee (Primary) and Lake Amador (Secondary)

Drinking Water Source Assessment information: A copy of the assessment can be obtained by contacting ACEHD at (209) 223-6439

Time and place of regularly scheduled board meetings for public participation: JVID Board Meetings are on the second Wednesday of the month at the JVID Office at 6:00pm. Website at <https://www.jvid.org/meetings>

For more information, contact: Steven Fredrick, Operations Manager Phone: (209) 304-7699

## TERMS USED IN THIS REPORT

|   |   |
|---|---|
| <p><b>Maximum Contaminant Level (MCL):</b> The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.</p> <p><b>Maximum Contaminant Level Goal (MCLG):</b> The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (U.S. EPA).</p> <p><b>Public Health Goal (PHG):</b> The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.</p> <p><b>Maximum Residual Disinfectant Level (MRDL):</b> The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.</p> <p><b>Maximum Residual Disinfectant Level Goal (MRDLG):</b> The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.</p> <p><b>Primary Drinking Water Standards (PDWS):</b> MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.</p> | <p><b>Secondary Drinking Water Standards (SDWS):</b> MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.</p> <p><b>Treatment Technique (TT):</b> A required process intended to reduce the level of a contaminant in drinking water.</p> <p><b>Regulatory Action Level (AL):</b> The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.</p> <p><b>Variances and Exemptions:</b> Permissions from the State Water Resources Control Board (State Board) to exceed an MCL or not comply with a treatment technique under certain conditions.</p> <p><b>Level 1 Assessment:</b> A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.</p> <p><b>Level 2 Assessment:</b> A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an <i>E. coli</i> MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.</p> <p><b>ND:</b> not detectable at testing limit</p> <p><b>ppm:</b> parts per million or milligrams per liter (mg/L)</p> <p><b>ppb:</b> parts per billion or micrograms per liter (µg/L)</p> <p><b>ppt:</b> parts per trillion or nanograms per liter (ng/L)</p> <p><b>ppq:</b> parts per quadrillion or picogram per liter (pg/L)</p> <p><b>pCi/L:</b> picocuries per liter (a measure of radiation)</p> |
|---|---|

**The sources of drinking water** (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

**Contaminants that may be present in source water include:**

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

**In order to ensure that tap water is safe to drink**, the U.S. EPA and the State Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

**Tables 1, 2, 3, 4, 5, and 6 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent.** The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

| TABLE 1 – SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA |                           |                            |  |      |                                      |
|---|---------------------------|----------------------------|--|------|--------------------------------------|
| Microbiological Contaminants<br>(complete if bacteria detected)       | Highest No. of Detections | No. of Months in Violation | MCL  | MCLG | Typical Source of Bacteria           |
| Total Coliform Bacteria<br>(state Total Coliform Rule)                | (In a month)<br>0         | 0                          | 1 positive monthly sample  | 0    | Naturally present in the environment |
| Fecal Coliform or <i>E. coli</i><br>(state Total Coliform Rule)       | (In the year)<br>0        | 0                          | A routine sample and a repeat sample are total coliform positive, and one of these is also fecal coliform or <i>E. coli</i> positive |      | Human and animal fecal waste         |
| <i>E. coli</i><br>(federal Revised Total Coliform Rule)               | (In the year)<br>0        | 0                          | (a)  | 0    | Human and animal fecal waste         |

(a) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

| TABLE 2 – SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER             |              |                          |  |                        |     |     |   |   |
|---|--------------|--------------------------|--|------------------------|-----|-----|---|---|
| Lead and Copper<br>(complete if lead or copper detected in the last sample set) | Sample Dates | No. of Samples Collected | 90 <sup>th</sup> Percentile Level Detected | No. Sites Exceeding AL | AL  | PHG | No. of Schools Requesting Lead Sampling | Typical Source of Contaminant   |
| Lead (ppb)  | July 2023    | 19                       | ND   | None                   | 15  | 0.2 | ----                                    | Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits |
| Copper (ppm)  | July 2023    | 19                       | 0.17                                       | None                   | 1.3 | 0.3 | Not applicable                          | Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives               |

| Chemical or Constituent (and reporting units) | Sample Date | Level Detected | Range of Detections | MCL  | PHG (MCLG) | Typical Source of Contaminant  |
|---|-------------|----------------|---------------------|------|------------|--|
| Sodium (ppm)                                  | 04/04/2023  | 2.5            | ----                | None | None       | Salt present in the water and is generally naturally occurring   |
| Hardness (ppm)                                | 04/04/2023  | 19             | ----                | None | None       | Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring |

| Chemical or Constituent (and reporting units) | Sample Date          | Level Detected                      | Range of Detections | MCL [MRDL]                         | PHG (MCLG) [MRDLG]                | Typical Source of Contaminant  |
|---|----------------------|-------------------------------------|---------------------|------------------------------------|-----------------------------------|--|
| Asbestos (MFL)                                | 06/23/2023           | ND                                  | ND                  | 7 MLF                              | 7 MLF                             | Internal corrosion of asbestos cement water mains; erosion of natural deposits   |
| Gross Alpha Particle Activity (pCi/L)         | 12/12/2022           | Pardee Reserve Raw<br>6.01+1.48     | ----                | 15                                 | (0)                               | Erosion of natural deposits  |
| Combined Radium (pCi/L)                       | 09/18/2023           | Pardee Reserve Raw<br>-0.0602+0.118 | ----                | 5                                  | (0)                               | Erosion of natural deposits  |
| Aluminum (mg/L)                               | 04/04/2023           | 0.15                                | ----                | 1                                  | 0.6                               | Erosion of natural deposits; residue from some surface water treatment processes |
| Chlorine (mg/L)                               | Sampled Monthly 2022 | 0.72 (Annual Average)               | <0.10 – 1.5         | [MRDL = 4.0 (as Cl <sub>2</sub> )] | [MRDLG = 4 (as Cl <sub>2</sub> )] | Drinking water disinfectant added for treatment                                  |
| TTHMs [Total Trihalomethanes] (µg/L)          | Quarterly 2022       | Average = 52.7                      | 45.8 – 62.7         | 80                                 | Not Available                     | Byproduct of drinking water disinfection   |
| HAA5 [Sum of 5 Haloacetic Acids] (µg/L)       | Quarterly 2022       | Average = 13.3                      | 10.3 – 11.9         | 60                                 | Not Available                     | Byproduct of drinking water disinfection   |

| Chemical or Constituent (and reporting units) | Sample Date | Level Detected | Range of Detections | SMCL     | PHG (MCLG) | Typical Source of Contaminant                               |
|---|-------------|----------------|---------------------|----------|------------|---|
| Color (Units)                                 | 04/04/2023  | 15             | ----                | 15 Units | NA         | Naturally-occurring organic materials                       |
| Iron (ug/L)                                   | 04/04/2023  | 240            | ----                | 300 ug/L | NA         | Leaching from natural deposits; industrial wastes           |
| Odor--- Threshold (Units)                     | 04/04/2023  | 4              | ----                | 3 Units  | NA         | Naturally-occurring organic materials                       |
| Turbidity (NTU)                               | 04/04/2023  | 5.3            | ----                | 5        | NA         | Soil runoff   |
| Total Dissolved Solids [TDS] (mg/L)           | 04/04/2023  | 43             | ----                | 1,000    | NA         | Runoff/leaching from natural deposits                       |
| Specific Conductance (µS/cm)                  | 04/04/2023  | 49             | ----                | 1,600    | NA         | Substances that form ions when in water; seawater influence |
| Chloride (mg/L)                               | 04/04/2023  | 1.6            | ----                | 500      | NA         | Runoff/leaching from natural deposits; seawater influence   |
| Sulfate (mg/L)                                | 04/04/2023  | 2.0            | ----                | 500      | NA         | Runoff/leaching from natural deposits; seawater influence   |

| Chemical or Constituent (and reporting units) | Sample Date | Level Detected | Range of Detections | Notification Level | Health Effects Language  |
|---|-------------|----------------|---------------------|--------------------|--|
| 1,2,3-Trichloropropane                        | 12/12/2022  | ND             | ND                  | None               | Some people who drink water containing 1,2,3-trichloropropane in excess of the MCL over many years may have an increased risk of getting cancer. |

**Additional General Information on Drinking Water**

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead-Specific Language: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. **Jackson Valley Irrigation District** is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you do so, you may wish to collect the flushed water and reuse it for another beneficial purpose, such as watering plants. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/lead>.

**Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement**

| VIOLATION OF A MCL, MRDL, AL, TT, OR MONITORING AND REPORTING REQUIREMENT |   |          |  |                         |
|---|---|----------|--|-------------------------|
| Violation   | Explanation                             | Duration | Actions Taken to Correct the Violation | Health Effects Language |
| Color   | Exceeding Secondary Drinking Water MCLs | -----    | None Taken                             | Aesthetic Concerns      |
| -----   | -----                                   | -----    | -----                                  | -----                   |

**For Systems Providing Surface Water as a Source of Drinking Water**

| TABLE 8 - SAMPLING RESULTS SHOWING TREATMENT OF SURFACE WATER SOURCES                                    |   |
|--|---|
| Treatment Technique <sup>(a)</sup><br>(Type of approved filtration technology used)                      | Conventional Filtration   |
| Turbidity Performance Standards <sup>(b)</sup><br>(that must be met through the water treatment process) | Turbidity of the filtered water must:<br>1 – Be less than or equal to <u>0.3</u> NTU in 95% of measurements in a month.<br>2 – Not exceed <u>1.0</u> NTU at any time. |
| Lowest monthly percentage of samples that met Turbidity Performance Standard No. 1.                      | 95%   |
| Highest single turbidity measurement during the year   | 0.22 NTU<br>November 30 <sup>th</sup> , 2023  |
| Number of violations of any surface water treatment requirements   | None  |

(a) A required process intended to reduce the level of a contaminant in drinking water.

(b) Turbidity (measured in NTU) is a measurement of the cloudiness of water and is a good indicator of water quality and filtration performance. Turbidity results which meet performance standards are considered to be in compliance with filtration requirements.

**Summary Information for Violation of a Surface Water TT**

| VIOLATION OF A SURFACE WATER TT |             |          |  |                         |
|---------------------------------|-------------|----------|--|-------------------------|
| TT Violation                    | Explanation | Duration | Actions Taken to Correct the Violation | Health Effects Language |
| -----                           | -----       | -----    | -----                                  | -----                   |

**Summary Information for Operating Under a Variance or Exemption**

**Summary Information for Federal Revised Total Coliform Rule  
Level 1 and Level 2 Assessment Requirements**

**Level 1 or Level 2 Assessment Requirement not Due to an *E. coli* MCL Violation**

Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We found coliforms indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) to identify problems and to correct any problems that were found during these assessments.

During the past year we were **not required** to conduct any Level 1 assessment(s). **None** of the Level 1 assessment(s) were completed. In addition, we were **not required** to take corrective actions and we completed **none** of these actions.

During the past year **none** of the Level 2 assessments were required to be completed for our water system. **None** of the Level 2 assessments were completed. In addition, we were **not** required to take corrective actions and we completed **none** of these actions.

**Level 2 Assessment Requirement Due to an *E. coli* MCL Violation**

*E. coli* are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Human pathogens in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a greater health risk for infants, young children, the elderly, and people with severely-compromised immune systems. We found *E. coli* bacteria, indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) identify problems and to correct any problems that were found during these assessments.

We were **not** required to complete a Level 2 assessment because we found **no** *E. coli* in our water system. In addition, we were **not** required to take corrective actions and we completed **none** of these actions.

Report prepared 03-01-2024 by Alpha Analytical Laboratories, Inc., using CCR Guidance for Water Suppliers available at, [http://www.waterboards.ca.gov/drinking\\_water/certlic/drinkingwater/CCR.html](http://www.waterboards.ca.gov/drinking_water/certlic/drinkingwater/CCR.html), employing due diligence with instructions given. Data contained in this report are based on the analytical results generated by Alpha Analytical Laboratories and its subcontract laboratories.